

Opinion # 002-08

Question:

Can a wet vet have a vertical drop, or any type of horizontal break in the wet vented portion of the drain?

Answer:

The OAPI Plumbing Advisory Committee reviewed your question and by vote, no, this drawing/arrangement is not approved. This was one of our more interesting questions and stirred a lot of discussion on the many reasons why it would not be approved.