

Committee Opinion

OPC Reference #607.3

Log # 0004-05

Date Received 9/21/05

Date to Committee 9/26/05

Date to Board 1/10/06

Approved to Released 1/10/06

QUESTION:

Is an expansion tank, the only device that can be used for thermal expansion, or can you use a ball cock that has a thermal expansion relief valve?

OPINION:

It is the opinion of this committee, that there are other types of approved devices that can be used for thermal expansion. Our answer is no.

Final Vote 3/7

This opinion is not meant to be a binding code interpretation.