


QUESTION:

In drawing, we have a laundry tub in the basement which needs to be pumped into the sanitary. I have plumbers that want to use this style of pump. Provided the piping is tied in correctly to the sanitary drain line, does this meet Ohio Plumbing Code without a trap and without a vent?

**OPINION:**

“By consensus, it is the opinion of this committee that this installation would not be approved. 1002.1 states that each plumbing fixture shall be trapped. 901.2.1 states that every trap and trapped fixture must be vented. Sec. 712.1 states that the min. trap size for laundry tray 1 1/2”

Final Vote 8/8

This opinion is not meant to be a binding code interpretation.