


Approved to Released 1/8/2008

QUESTION:

In drawing we have a sealed sump crock with fixtures dumping into it. Do to the difficulty of getting a vent above the flood rim of the highest fixture upstairs, is it legal to tie the vent back into a stack as shown?

**OPINION:**

"By consensus, it is the opinion of this committee that a vent cannot connect to a soil or waste pipe. It must extend at least 6" above the flood level rim of the highest trap or trapped fixture and it must tie into a vent pipe, not a soil or waste pipe. As shown in drawing, this is not a legal installation.

Final Vote 11/11

This opinion is not meant to be a binding code interpretation.